Licensee - NESCO LTD						OERC FORM P.1	
Voltage Fluctuation							
(DISTCO)							
Period	**First six months of the previous year 2007-2008**		**Last six months of the previous year 2007-2008**		**First six months of the current year 2008-2009**		**Corrective Measures Proposed**
	Percentage of time		Percentage of time		Percentage of time		
Substation wise	when voltage was		when voltage was		when voltage was		
At 33Kv side of transformer	Below (9%)	Above (6%)	Below (9%)	Above (6%)	Below (9%)	Above (6%)	
(Incoming point of 33Kv bus)							
Balasore	17	0	15	0	19	0	
Bhadrak	20	0	21	0	22	0	
Soro	17	0	19	0	20	0	
Jaleswar	17	0	18	0	20	0	
Baripada	16	0	15	0	17	0	
Rairangpur	13	0	11	0	12	0	
Joda	5	2	8	1	7	0	
Polasponga	6	1	5	0	6	0	
Jajpur Road	5	0	6	0	4	0	
Duburi	5	1	4	2	5	1	
Jajpur Town	13	0	10	0	11	0	
Chandikhole	6	0	5	0	7	0	
NESCO AS A WHOLE	**12**	**0**	**11**	**0**	**13**	**0**	